

**United States Environmental Protection Agency
Region III
POLLUTION REPORT**

Date: Wednesday, March 23, 2005

From: Charlie Fitzsimmons, OSC

Subject: Continuation of Work
Sykesville Oil Spill
580 Obrect Rd, Sykesville, MD
Latitude: 39.3839
Longitude: -76.9783

POLREP No.: 6	Site #: E043Z1
Reporting Period: February and March 2005	D.O. #:
Start Date:	Response Authority: OPA
Mob Date:	Response Type: Emergency
Completion Date:	NPL Status: Non NPL
CERCLIS ID #:	Incident Category: Removal Action
RCRIS ID #:	Contract #
FPN# E043Z1	Reimbursable Account #

Site Description

refer to previous polreps 1-5.

Current Activities

Work continues on the investigatory front and the seep remediation.

A sample (#05-089-1) of product forwarded to the USCG COIL Lab in Groton Conn., revealed the material to be a light diesel fuel with some weathering. A sample from monitoring well MWA01 (#05-101-1), located within 50 feet and downgradient of an abandoned above ground storage tank farm (3 tanks) on the Fogle's property revealed a match. According to the lab "Suspected source sample 05-101-1 and spill sample 05—089-1 are derived from a common source petroleum oil. Differences noted are attributable to weathering". MWA01 well is located in an area immediately downslope of Fogle's, specifically the former AST location, that could logically be inferred as being derived from a spill below that AST. This is supported further by the results of the Geoprobe assessment indicating high PID readings at considerable depth. Visually, the product sample collected from MWA01 was similar to that previously submitted.

On March 21, 2005, the FOSC presented these findings to the USCG NPFC Case Officer and EPA Regional Counsel. FOSC met with Fogle's ownership on 3/31 to communicate findings and to advise that the area below the abandoned ASTs be opened up for sample. The present Access Agreement allows for EPA to perform this excavation should Fogle's be unable or unwilling to perform.

In addition to this investigatory activity, the USACE contractor (Plexus) will initiate a seep removal action. There is an identifiable slug of this light diesel sitting just below the surface at the seep area. On 02/22/05 the FOSC directed the USACE to provide a plan for removal of this slug, estimated to be between 5000 and 10,000 gallons. The proposed action will include the vacuuming

of the product from an interceptor trench, to be constructed during the week of 03/21/05, and transport offsite for disposal.

FOSC continues to participate in regular update meetings with property owners specifically Episcopal Ministry for the Aging (EMA), whose property the seep is emanating from. The next scheduled meeting is 03/30/05.

Planned Removal Actions

see above

www.epaosc.org/sykesvilleoil